Don E. Grissette Vice President Southern Nuclear
Operating Company, Inc.
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201

Tel 205.992.6474 Fax 205.992.0341

March 2, 2005

Docket Nos.: 50-424

50-425

SOUTHERN COMPANY

Energy to Serve Your World

NL-05-0317

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D. C. 20555-0001

> Vogtle Electric Generating Plant 10 CFR 21 Interim Report Cutler-Hammer Freedom Series Model C306 Thermal Overload Relays and Heater Packs

### Ladies and Gentlemen:

In accordance with 10 CFR 21.21(a)(2), Southern Nuclear Operating Company hereby provides the enclosed interim report for Vogtle Electric Generating Plant. The report pertains to Cutler-Hammer Freedom Series Model C306 Thermal Overload Relays and Heater Packs supplied by Framatome ANP, Inc., for which evaluation of reportability can not be completed within 60 days from discovery. The evaluation completion date is scheduled for April 29, 2005.

This letter contains no NRC commitments. If you have any questions, please advise.

Sincerely,

Don E. Grissette

DEG/TMM/sdl

Enclosure: 10 CFR 21 Interim Report

cc: Southern Nuclear Operating Company

Mr. J. T. Gasser, Executive Vice President

Mr. W. F. Kitchens, General Manager - Plant Vogtle

RType: CVC7000

U. S. Nuclear Regulatory Commission

Dr. W. D. Travers, Regional Administrator

Mr. C. Gratton, NRR Project Manager - Vogtle

Mr. G. J. McCoy, Senior Resident Inspector - Vogtle

IE19

#### -Enclosure

# Vogtle Electric Generating Plant 10 CFR 21 Interim Report Cutler-Hammer Freedom Series Model C306 Thermal Overload Relays and Heater Packs

The following 10 CFR 21 interim report is provided by Southern Nuclear Operating Company (SNC) for Vogtle Electric Generating Plant (VEGP) in accordance with 10 CFR 21.21(a)(2):

(i) Name and Address of Individual Making Interim Report

Mr. Don E. Grissette, Vice President Southern Nuclear Operating Company 40 Inverness Center Parkway Post Office Box 1295 Birmingham, AL 35201

(ii) Identification of Basic Component

Cutler-Hammer Freedom Series Model C306 Thermal Overload Relays and Heater Packs

(iii) Basic Component Supplier

Framatome ANP, Inc. 200 West Kensinger Drive Suite 600 Cranberry Township, PA 16066

(iv) Date of Discovery of Deviation

January 3, 2005

(v) Nature of Deviation

Cutler-Hammer Freedom Series Model C306 Thermal Overload Relays and Heater Packs supplied by Framatome are used at VEGP in some applications as containment penetration conductor primary protection. Accordingly, it is necessary in such applications that all three phases trip properly. During pre-installation testing of several thermal overload relays with different model heater packs, instances were found where single and multiple overload relay phases would trip either early, late, or not at all.

## Enclosure

Vogtle Electric Generating Plant 10 CFR 21 Interim Report Cutler-Hammer Freedom Series Model C306 Thermal Overload Relays and Heater Packs

## (vi) Evaluation Status

SNC is continuing to evaluate the deviation to fully characterize the issue. SNC is currently working with Framatome to review the VEGP site pre-installation testing program that is used for the Cutler-Hammer Freedom Series Model C306 Thermal Overload Relays and Heater Packs in an effort to determine if there is a manufacturing defect associated with these components.

(vii) Evaluation Scheduled Completion Date

April 29, 2005